

# Certificate

This is to certify that **Firebox Australia Pty Ltd**

ABN 75 116 370 793

Head Office Address Lot 5 / 19 Balook Drive  
Beresfield, New South Wales, 2322  
Australia

Holds Certificate Number **BMP 520107**

Is authorised to use the BSI registered Benchmark Product Certification Trademark, on products identified in the Product Certification Schedule that is attached to this Product Certification Certificate. Such products have been Type Tested and are manufactured under the Product Certification Requirements monitored by BSI to ensure that the manufacturing process has the capability to consistently produce products in compliance with and are Certified to:

AS/NZS 1841.2:2007 Portable fire extinguishers - Specific requirements for water type extinguishers

For and on behalf of BSI

Marc Barnes, Managing Director, BSI Group ANZ Pty Ltd

Originally registered  
23/03/2006

Latest issue  
23/12/2021

Expiry date  
22/01/2026



...making excellence a habit.

# Schedule

This schedule supports the Product Certification Certificate for

Firebox Australia Pty Ltd

ABN

75 116 370 793

Head Office Address

Lot 5 / 19 Balook Drive  
Beresfield, New South Wales, 2322  
Australia

Holds Certificate Number

BMP 520107

Standard

AS/NZS 1841.2:2007 Portable fire extinguishers - Specific requirements for water type extinguishers

Issue date

23/12/2021

Model	BSI Review Date	Description
FB90AW	12/12/2016	9.0 Litre water type stored pressure fire extinguisher Class 3A
FB9LF-500	15/02/2021	9.0 Litre water type with F-500 encapsulating agent. Ratings 3A:10B:4F
FB4LF-500	29/06/2021	4.0 Litre water type fire extinguisher with F-500 encapsulating agent Ratings 2A:2B:3F