

Verification Certificate

This is to certify that
Firebox Australia Pty Ltd
Lot 5 / 19 Balook Drive
Beresfield, New South Wales, 2322
Australia

Holds Certificate Number **VC 763126**

In respect of:

A Witness Assessment of the fire testing of the Portable Fire Extinguishers
- Model FB4LF-500 with a 2400W/h lithium ion batteries pack fire
- Model FB9LF-500 with a 4800W/h lithium ion batteries pack fire

Viewed and confirm that both battery pack fires were extinguished

Technical file BSI/AUST/00739 dated 24 September 2021

For and on behalf of BSI



Marc Barnes, Managing Director, BSI Group ANZ Pty Ltd

Originally registered
17/02/2022

Latest issue
08/03/2022

Expiry date
16/02/2025



...making excellence a habit.