

5<sup>th</sup> July 2022

FireBox Australia Pty Ltd  
Lot 5/19 Balook Drive  
Beresfield  
New South Wales, 2322  
Australia

Re: Letter for certification.

Dear Steven,

This letter is to confirm BSI has certified a range of Water Type Portable Fire Extinguishers using a 3% F-500 Encapsulating Agent, reference BMP 520107, the items have been fully tested and certified by BSI Australia.


As these are water based the certification was based on clause 1.2 New Designs and Innovations according to AS/NZS 1841.1:2007 (R2021).

There are no false claims for the extinguisher type and ratings, the extinguisher and its medium are specifically innovated to extinguish A, B, F and Lithium-Ion battery fires.

As Lithium-Ion batteries are a DC source and not AC there are no issues in relation to being electrocuted. However, a water-based F-500 extinguisher has been tested and complies to EN 3 for an E class fire. BSI is confident testing will show compliance once testing has been completed, no claims are made in relation to an E rating.

If you require any further information or clarification, please do not hesitate to contact me directly.

Yours sincerely,



Paul Roberts  
Product Certification Manager Australia / New Zealand BSI Group  
[paul.roberts@bsigroup.com](mailto:paul.roberts@bsigroup.com)  
Mobile: +61 410 564 505  
Land Line: +61 3 9816 6111