

Test Report No.: HNFS2204000059FP Date: APR.29.2022 Page 1 of 6

Firebox Australia Pty Itd

Lot 5, 19 Balook Drive, Beresfield NSW 2322 Australia

Sample Description: FIRE EXTINGUISHER

Type/Style: Gecko FB4LF-500 **Manufacturer: Power Saints Ltd** Supplier: Powder Saints Ltd

Country of Destination: Australia Buyer: Firebox Australia Pty Ltd

End use application: Fire extinguishing

The above data and information was / were submitted and identified on behalf of the client. SGS is not responsible for the authenticity, integrity and results of the data and information and / or the validity of the conclusion.

Sample Receiving Date: 2022-04-20

Test Performing Date: 2022-04-25 TO 2022-04-27

Test Requested:

Electrical conductivity of extinguisher discharge perform on 1kV*, 5kV*

Test Results:

| No. | Test Items: | Test | Note |
|-------|---|----------|---|
| | | Results: | |
| 01 | Electrical conductivity of extinguisher | PASS | When the extinguisher is in operation |
| | discharge perform on 1kV* | 1 700 | and the metallic plate is live, the current between the handle and earth, and between the nozzle and earth, shall be not more than 0.5mA at any time during the complete discharge of the fire extinguisher.* |
| 02 | Electrical conductivity of extinguisher | | |
| | discharge perform on 5kV* | FAIL | |
| *: Cu | stomer Requirements | - 1 | |

⁻⁻See attached sheet--

Signed for and on behalf of

Henan Tongjia Quality Testing And Technical Service Company Limited

Field Zhang/张琪 Approved signatory

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.and. for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-en-Document.aspx.Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction document. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawfull and offenders may be prosecuted to the fullest extent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CND.Doccheck@sos.com

Room H501, E3 Testing Building, the intersection of Boxue East Road and Baifo Nan Road, Zhengzhou, Henan, China 450047 t (86-371) 89933189 f (86-371) 89933190



Test Report No.: HNFS2204000059FP Date: APR.29.2022 Page 2 of 6

1. INTRODUCTION

Test the current when water-based extinguishers use on energized electrical equipment fires.

2. SUMMARY

The 4 sets Water-based extinguishers test results

| No. | Test voltage | Result |
|-----|--------------|--------|
| 1# | 1kV | 0.07mA |
| 2# | 1kV | 0.08mA |
| 3# | 5kV | 0.55mA |
| 4# | 5kV | 0.61mA |



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions of New Policy Indiana, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Cilent's instructions, if any. The Company's sole responsibility is to its Cilent and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fulles tent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CAI.Doccheck@ss.com

Room H501, E3 Testing Building, the intersection of Boxue East Road and Baifo Nan Road, Zhengzhou, Henan, China 450047 t (86-371) 89933189 f (86-371) 89933190



Test Report No.: HNFS2204000059FP Date: APR.29.2022 Page 3 of 6

3. SPECIMEN CONSTRUCTION AND INSTALLATION

- **3.1** Hang a metal plate of dimensions $(1 \text{ m} \pm 25 \text{ mm}) \times (1 \text{ m} \pm 25 \text{ mm})$, vertically from insulating supports. Connect the plate to a transformer so that an alternating voltage of 1 kV is established between the plate and earth, and then test the voltage of 5Kv.
- **3.2** Mount the extinguisher on an insulating support with the nozzle fixed 1 m from the centre of the plate, at right angles to it and directed towards it. Connect the extinguisher to the earth. In the case of an extinguisher with a hose, connect it to the earth by connection at the nozzle. For an extinguisher not fitted with a hose, the connection is at the handle.

4 TEST PROCEDURE

Measure any current flowing between the handle or the nozzle and earth and between earth and the extinguisher at any time during the complete discharge when the plate is live.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company, Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fulless extent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 83071443.

Attention: 16 check the authenticity of testing /inspection report & certificate, please contact us at telephone: (eeor email: CN_Doccheck@sgs.com

[Room H501.E3 Testing Building the intersection of Boxue East Road and Baifo Nan Road, Zhengzhou, Henan, China 450047 www.s

t (86–371) 89933189 f (86–371) 89933190



Test Report No.: HNFS2204000059FP Date: APR.29.2022 Page 4 of 6

TEST DATA AND OBSERVATION 5.

| No. | Test voltage | the current between the handle or the nozzle and earth | the current between earth and the extinguisher |
|-----|--------------|--|--|
| 1# | 1kV | 0.07mA | 0.07 mA |
| 2# | 1kV | 0.08 mA | 0.08 mA |
| 3# | 5kV | 0.55 mA | 0.55 mA |
| 4# | 5kV | 0.61 mA | 0.61 mA |

CONCLUSION 6.

The extinguisher is in operation and the metallic plate is live, the current between the handle or the nozzle and earth and between earth and the extinguisher at any time during the complete discharge:

| No. | Test voltage | Result |
|-----|--------------|--------|
| 1# | 1kV | 0.07mA |
| 2# | 1kV | 0.08mA |
| 3# | 5kV | 0.55mA |
| 4# | 5kV | 0.61mA |

7. **LIMITATION**



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at https://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx.attention.spx.a

Room H501, E3 Testing Building, the intersection of Boxue East Road and Baifo Nan Road, Zhengzhou, Henan, China 450047



Test Report No.: HNFS2204000059FP Date: APR.29.2022 Page 5 of 6

sThe results only relate to the behaviour of the sample of the element of construction under the particular conditions of the test. They are not intended to be the sole criteria for assessing the potential fire performance of the element in use nor do they reflect the actual behaviour in fires.

The test results relate only to the sample tested. The performance of sample may change if different specifications.

SGS is not responsible for the authenticity, integrity and results of the information which provided by client and / or the validity of the conclusion.

8. APPENDIX 1 PHOTO

APPENDIX 1 PHOTO





Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.apx and, for electronic format documents, subject to Terms and Conditions ferms-e-Document as the Title; http://www.sgs.com/en/Termd-Conditions/Terms-e-Document.apx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction forcement cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawfull and offenders may be prosecuted to the fullest extend to the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN_Doccheck@sac.com

Room H501, E3 Testing Building, the intersection of Boxue East Road and Baifo Nan Road, Zhengzhou, Henan, China 450047 t (86–371) 89933189 f (86–371) 89933190



No.: HNFS2204000059FP Date: APR.29.2022 Page 6 of 6





Fig.5 1kV-Sample1



Fig.6 1kV-Sample 2



5kV- Sample 3 Fig.7

Fig.8 5kV- Sample 4

SGS authenticate the photo on original report only ***End of Report***



▲高压,

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.agpx, and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Ferms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Cilent's instructions, if any. The Company's sole responsibility is to its Cilent and this document does not exonerate parties to a transaction form exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawfull and offenders may be prosecuted to the fulles tent of the law.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CND poccheck@ass.com

Room H501, E3 Testing Building, the intersection of Boxue East Road and Baifo Nan Road, Zhengzhou, Henan, China 450047 t (86-371) 89933189 f (86-371) 89933190